Certificate

kiwa
Partner for progress

Number	88786/01	Replaces	--
Issued	15-07-2015	Scope	2009/142/EC 92/42/EEC
Report number	141200646/2		
PIN	0063CP3646	Contract number	E 8090

EC TYPE EXAMINATION CERTIFICATE

Kiwa hereby declares that the **Central Heating Boilers**, types

Hermann MICRAPLUS CONDENS 25 -A (H-ES)
Hermann MICRAPLUS CONDENS 30 -A (H-ES)

Supplied by **Saunier Duval Dicosa S.A.**
Zamudio, Spain

meet the essential requirements as described in the
Directive 2009/142/EC relating to appliances burning gaseous fuels and the **Directive 92/42/EEC on efficiency requirements.**

Country of destination, appliance categories, installation types and available types are mentioned in the appendix to this certificate.

Bouke Meekma
Kiwa

kiwa Approved
EC Directive
EC TYPE EXAMINATION
2009/142/EC
92/42/EEC
GASTEC

CE 0063

Kiwa Nederland B.V.
Wilmersdorf 50
P.O. Box 137
7300 AC APELDOORN
The Netherlands
www.1kiwa.com

GASTEC

RvA PRODUCTS RvA C 002

CERTIFICATE 88786/01

Appendix no.: 1
Dated: July 2015
Examination report(s): 141200646/2

List of available types.

Type name	Appliance type	CH Heat input (kW - Hi)	DHW Heat input (kW - Hi)
MICRAPLUS CONDENS 25 -A (H-ES)	C13, C33, C43, C53, C83, C93, B33, B53P	5.1 – 18.4	5.1 – 25.7
MICRAPLUS CONDENS 30 -A (H-ES)	C13, C33, C43, C53, C83, C93, B33, B53P	6.1 – 25.5	6.1 – 30.6

Directives
Gas Appliance Directive (2009/142/EC)
Boiler Efficiency Directive (92/42/EEC)

Standard
EN 15502-1:2012, EN 15502-2-1: 2012

Appliance category
I2H G20 - 20mbar

Countries of destination
Spain (ES)