



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-7301BS0260

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	ISOTUBI S.L. C/Mecànica 6 Pol. Ind. Santa Rita, E-08755 Castellbisbal (Barcelona)
Distributor <i>Vertreiber</i>	ISOTUBI S.L. C/Mecànica 6 Pol. Ind. Santa Rita, E-08755 Castellbisbal (Barcelona)
Product Category <i>Produktart</i>	stainless tubes: stainless steel tube (7301)
Product Description <i>Produktbezeichnung</i>	tube made of stainless steel for the drinking water installation, materials: 1.4401; 1.4404; 1.4521
Model <i>Modell</i>	NUMEPRESS
Test Reports <i>Prüfberichte</i>	laboratory control test: 18010118-1 from 31.03.2017 (TSZ) supplement test: 2261161-1 from 04.02.2015 (TSZ) type testing: 600011056 from 21.12.2012 (TSZ) supplement test: 1774219 from 25.05.2012 (TSZ) supplement test: 1547093 from 07.09.2010 (TSZ) type testing: 983498 from 18.06.2007 (TSZ)
Test Basis <i>Prüfgrundlagen</i>	DVGW GW 541 (01.10.2004)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	18.06.2022 / 17-0425-WNR



70028-04-A-DE

17.10.2017 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
NUMEPRESS	manufacturing group: 15,0 up to 54,0 mm	according to GW 541, table 2
NUMEPRESS	manufacturing group: 12,0 up to 108,0 mm	according to GW 541, table 3
NUMEPRESS	manufacturing group: 114,3 up to 168,3 mm	according to GW 541, table 4

Hints of Utilization / Remarks
Verwendungshinweise / Bemerkungen

tested diameters according to GW 541, table 2, materials: 1.4401; 1.4404
15,0 mm; 18,0 mm; 22,0 mm; 28,0 mm; 35,0 mm; 42,0 mm; 54,0 mm

tested diameters according to GW 541, table 3, materials: 1.4401; 1.4404
12,0 mm; 15,0 mm; 18,0 mm; 22,0 mm; 28,0 mm; 35,0 mm; 42,0 mm; 54,0 mm; 76,1 mm; 88,9 mm; 108,0 mm

tested diameters according to GW 541, table 3, material: 1.4521
12,0 mm; 15,0 mm; 18,0 mm; 22,0 mm; 28,0 mm; 35,0 mm; 42,0 mm; 54,0 mm

tested diameters according to GW 541, table 4, materials: 1.4401; 1.4404
114,3 mm; 139,7 mm; 168,3 mm
